

Chemiteq Limited
Unit 20 Arkwright Court
Astmoor Industrial Estate
Runcorn
Cheshire WA7 1NX
UK

Deres ref:
Vår ref: 2016/10697
Dato: 14 March 2016
Org.nr: 985 399 077

Att: Angela Riding

Statens tilsyn for planter, fisk, dyr og næringsmidler



Approval of chemical product for drinking water treatment

We refer to your application for approval of Oxyl-Pro as a product for drinking water treatment.

The Norwegian Food Safety Authority are doing the formal approval of these products, based on a toxicological evaluation by the Norwegian Institute of Public Health. The approved products are subsequently added to the list of approved chemical products for drinking water treatment, at www.mattilsynet.no.

Decision

The Norwegian Food Safety Authority hereby approves Oxyl-Pro as a drinking water treatment product that penetrate and break up biological deposits such as biofilm, due to the oxidizing effect of the hydrogen peroxide. Oxyl-Pro is now listed among the approved chemical products for drinking water treatment, under the category "disinfectants".

The approval is issued pursuant to Regulations Concerning Water Supply and Water Intended for Human Consumption, Section 15, and based on information in the application.

The significance of the approval is that the Norwegian Food Safety Authority do not consider it likely that this product will pose a health risk used in drinking water as long as the instructions are followed. The approval implies no guarantee of the water treating effect claimed, and must therefore not be used in marketing purposes with this regard.

The approval is valid for 10 years if the product and its instructions for use are unchanged. After these 10 years the approval automatically becomes invalid.

Appeal

The applicant can appeal the decision, in accordance with the Public Administration Act, Section 28. Appeals must be sent the Norwegian Food Safety Authority within three weeks of receipt of this letter.

Best regards


Nina Krefting Aas
Head of Section

www.mattilsynet.no

Mattilsynet
Hovedkontoret

Saksbehandler: Line Ruden
E-post: postmottak@mattilsynet.no
(Husk mottakers navn)

Postadresse:
Felles postmottak, Postboks 383
2381 Brumunddal